

**UNIVERSAL**

FIRE AND SAFETY SERVICES LTD.

An ISO 9001-2015 Certified Company

FORM B

SEE SECTION 3(3) AND RULE 4 (2)

SIX MONTHLY CERTIFICATES TO BE GIVEN IN EVERY JULY AND DECEMBER BY THE OWNER OR THE OCCUPIER FOR COMPLIANCE OF THE FIRE PREVENTION AND LIFE SAFETY MEASURES:

CERTIFICATE

Certified that I | We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises, namely:

M/S. NEW HORIZON PUBLIC SCHOOL
Plot No07, Sector 19, Airoli Navi Mumbai

I | We further certify that these installations in the above-mentioned buildings are maintained in good repair and efficient condition during the period **1st JULY 2023 to 31st DECEMBER 2023** as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measure Act 2006 (Mah.III Of 2007).

The details of the inspection of installations carried out by me | us are mentioned in the report appended here with.

Place: Mumbai
Date: 09.01.2024
Outward Ref.: UFSSL/B/461

For Universal Fire & Safety Services Ltd.

RAHUL
ASHOK
LONDHE

Digitally signed
by RAHUL ASHOK
LONDHE
Date: 2024.01.09
15:11:21 +05'30'

Authorised Signatory.

License No. MFS / LA / RF-39 / RD-34 / RP-08


जा.क. - 74/2024
दिनांक 06/02/2024
'ब' प्रमाणपत्र दाखल करून घेण्यात आले
अग्निशमन विभाग
नवी मुंबई महानगरपालिका



Handwritten signature of the Principal

PRINCIPAL
NEW HORIZON PUBLIC SCHOOL
AIROLI, NAVI MUMBAI

Handwritten signature of the Manager
Manager

	नवी मुंबई महानगरपालिका अग्निशमन विभाग	Navi Mumbai Municipal Corporation Fire Brigade Department
	सेक्टर-१६ अ, वाशी, नवी मुंबई, ४००७०३ दूरध्वनी क्र : वाशी-०२२-२७६६०१०१, १०१ सीबीडी-०२२-२७५७२११, १०२ ऐरोली-०२२-२७७१६६०० नेरुळ - ०२२-२७७०७१०१	Sector -16A, Vashi, Navi Mumbai - 400703 Tel No. Vashi - 022-27660101, 101 CBD - 022-27572111, 102 Airoli - 022- 27796600 Nerul - 022-27707101

INSPECTION REPORT OF FIXED FIRE PROTECTION SYSTEM

Name of the Society :- M/s. New Horizon public School
 Address :- Plot No. ०७, Sector- 19, Airoli.
 Type of Occupancy :- Residential School
 Number of floors :- Ground + upper floors
 Date of Inspection :- 16/11/2024

Sr.No.	Items	Quantity	Remark
1	Wet Riser-cum down comer (5inch)	०१ No.	The fixed fire protection system is in good working conditions on day of inspection OK
2	Landing valve (Single type)	०१ No.	
3	RRL type Canvas Hose with Hose Box	०१ No.	
4	Gun metal Nozzle	०१ No.	
5	Hose reel with shut-up Nozzle	०१ No.	
6	Under ground water tank for fire fighting	०१ No.	
7	Over Head water tank for fire fighting	०१ No.	
8	Electrical main pump for fire fighting	०१ No.	
9	Electrical standby pump for fire fighting	No No.	
10	Jockey pump for fire fighting	No No.	
11	Booster pump for fire fighting	०१ No.	
12	D.G.Set	No No.	
13	Courtyard Hydrant	०३ No.	
14	Siamese Connection	०१ No.	
15	Sprinkler System	No No.	
16	Smoke Detectors	No No.	
17	Alarm system with MCP & hotter.	No No.	
18	ABC fire extinguisher- 5 kgs capacity ५५९	२५ No.	O.K.
19	Co2 Gas fire extinguisher- २ kgs capacity ०२/५५९	०५ No.	

Assistant Station Officer
 Navi Mumbai Municipal Corporation
 नवी मुंबई महानगरपालिका
 अग्निशमन केंद्र ऐरोली

PRINCIPAL
 NEW HORIZON PUBLIC SCHOOL
 AIROLI, NAVI MUMBAI

Manager