



नवी मुंबई  
महानगरपालिका

Navi Mumbai  
Municipal Corporation

पर्यावरण प्रयोगशाळा  
अग्रोळी पुलाखाली, सी.बी.डी. बेलापूर, नवी मुंबई 400 614.  
दुरध्वनी क्र. : 2757 9882



NMMC/Environment Laboratory/143/2023-2024

Date : 18/03/2024

Date of sample received. : 18/03/2024 Date of sample testing : 18/03/2024 to 20/03/2024

Customer's Name and Location : New Horizone Public School  
Sec - 19, Airoli,  
Navi Mumbai - 400708

**TEST REPORT**

Sr. No.	Testing Parameter	Test Result	Test Standards ( IS 10500 : 2012 )
01	pH	7.2	6.5 - 8.5
02	Turbidity	0.0	Max. 5.0 N.T.U.
03	Residual Chlorine	0.1	Min. 0.2 mg/l
04	Bacteriological Test		
	Total Coliforms	0	0 per 100 ml
	E. Coli	- ve	- ve
	F. Coli	- ve	- ve

Test Report No. : 143

Date : 20 /03/2024

Conclusion : Test results of the sample are based on the sample submitted in the laboratory.



Lab Chemist

Lab Incharge

Environment Laboratory

Navi Mumbai Municipal Corporation

PRINCIPAL  
NEW HORIZON PUBLIC SCHOOL  
AIROLI, NAVI MUMBAI

Manager





## Certification for Sanitary and Drinking Water

This is to certify that New Horizon Public School, Sect 19. Airoli, Navi Mumbai-School Campus and the surrounding is very conducive for the children and the staff. Each of the several classes is sufficient for the maximum number of pupils. The classrooms are spacious, properly ventilated and lighted. The building and surrounding are kept neat and clean. The latrines and urinals are provided adequately and maintained well. There is sufficient amount of drinking water available. In all respect, the sanitation is good.

This certificate is issued on the specific request of the New Horizon Public School, Airoli

Medical Officer

UHP Rabada

Navi Mumbai Municipal Corporation

वैद्यकीय अधिकारी  
नागरी प्रथमिक आरोग्य केंद्र, राबाडा  
नवी मुंबई महानगरपालिका

PRINCIPAL

NEW HORIZON PUBLIC SCHOOL  
AIROLI, NAVI MUMBAI

Manager